

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on May 30)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/5/30 12:00	2011/5/30 12:10	2011/5/30 12:15	2011/5/30 11:48	2011/5/30 11:50	2011/5/30 11:40	2011/5/30 10:05
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	4.1E+00	6.0E+00	ND	2.3E-01	ND	ND	ND
Cs-134 (about 2 years)	7.4E+01	1.6E+01	1.6E-01	1.5E-01	ND	1.3E-02	ND
Cs-137 (about 30 years)	8.8E+01	1.9E+01	1.4E-01	1.6E-01	ND	2.0E-02	ND

. E - means . ×10.

Data of other nuclides are under evaluation.