Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <1/3>
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 4)

Place of Collection	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Unit 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the
Time and date of sample collection	2011/6/3 6:28 AM		2011/6/3 6:32 AM		2011/6/3 6:45 AM		2011/6/3 6:40 AM		2011/6/3 6:59 AM		
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	27	0.68	180	4.5	230	5.8	200	5.0	310	7.8	40
Cs-134 (about 2 years)	270	4.5	470	7.8	640	11	730	12	720	12	60
Cs-137 (about 30 years)	270	3.0	490	5.4	690	7.7	780	8.7	740	8.2	90

<sup>&</sup>quot;Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>". Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

## The Results of Nuclide Analyses of Radioactive Materials in the Seawater <2/3> Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 4)

Place of Collection	Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the
Time and date of sample collection	2011/6/3 6:50 AM		2011/6/3 7:08 AM		2011/6/3 7:02 AM		2011/6/3 7:18 AM		2011/6/3 7:10 AM		
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	1,700	43	250	6.3	260	6.5	150	3.8	98	2.5	40
Cs-134 (about 2 years)	5,000	83	720	12	5,700	95	680	11	830	14	60
Cs-137 (about 30 years)	5,300	59	780	8.7	6,100	68	730	8.1	860	9.6	90

<sup>&</sup>quot;Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>". Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <3/3>
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 4)

Place of Collection  Time and date of sample collection	Inside the south of 1F's Unit 1-4 Water Intake Canal 2011/6/3 7:25 AM										Density limit by the announcement of Reactor Regulation (Bq/L)
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	- (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	85	2.1									40
Cs-134 (about 2 years)	710	12									60
Cs-137 (about 30 years)	760	8.4									90

<sup>&</sup>quot;Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>". Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1