

Results of Nuclide Analysis of Seawater <Coast>

Reference

(Data summarized on 6/10)

Place of Sampling	North of Discharge Channel of 5-6u of 1F (approx. 30m north of 5-6u discharge channel)				Around South Discharge Channel of 1F (approx. 330m south of 1-4u Discharge Channel)				Around North Discharge Channel of 2F (Around 3,4u Discharge Channel) (approx. 10 km from 1F)		Around Iwasawa Shore of 2F (approx. 7 km south of 1,2u Discharge Channel) (approx. 16 km from 1F)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and Date of Sample Collection	2011/06/09 8:25		2011/06/09 13:40		2011/06/09 9:10		2011/06/09 13:25		2011/06/09 8:20		2011/06/09 7:55		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	37	0.62	37	0.62	33	0.55	28	0.47	16	0.27	14	0.23	60
Cs-137 (about 30 years)	19	0.21	33	0.37	28	0.31	28	0.31	ND	-	ND	-	90

Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm³ to Bq/L

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below measurable limit (approximately 6Bq/L for I-131), "ND" is stated.

Detection limits of the three main nuclides are as follows: I-131: approx. 6Bq/L, Cs-134: 15Bq/L, Cs-137: 15Bq/L

However, detection limits differs depending on the detectors and samples types, and therefore may be detected, under figures below.

Results of Nuclide Analysis of Seawater <Offshore 1/2>

Reference

(Data summarized on June 10)

Place of Sampling	3 km offshore of Haramachi-ku Upper layer		3 km offshore of Haramachi-ku Lower layer		3 km offshore of Odaka-ku Upper layer		3 km offshore of Odaka-ku Lower layer		3 km offshore of Iwasaki Shore Upper layer		3 km offshore of Iwasaki Shore Lower layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and Date of Sample Collection	2011/6/9 8:45	2011/6/9 8:45	2011/6/9 9:00	2011/6/9 9:00	2011/6/9 7:55	2011/6/9 7:55						
Detected Nuclides (Half-life)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	
	I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	8 km offshore of Odaka-ku Upper layer		8 km offshore of Odaka-ku Lower layer		8 km offshore of Iwasawa Shore Upper layer		8 km offshore of Iwasawa Shore Lower layer						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and Date of Sample Collection	2011/6/9 9:15	2011/6/9 9:15	2011/6/9 8:20	2011/6/9 8:20								
Detected Nuclides (Half-life)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	
	I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-				
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-					60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-					90

Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below measurable limit (approximately 6Bq/L for I-131), "ND" is stated.

Detection limits of the three main nuclides are as follows: I-131: approx. 6Bq/L, Cs-134: 15Bq/L, Cs-137: 15Bq/L

However, detection limits differs depending on the detectors and samples types, and therefore may be detected, under figures below.

Results of Nuclide Analysis of Seawater <Offshore 2/2>

Reference

(Data summarized on June 10)

Place of Sampling	North Iwaki Offshore 3km Upper Layer		North Iwaki Offshore 3km Lower Layer		Natsui-gawa Offshore 3km Upper Layer		Natsui-gawa Offshore 3km Lower Layer		Onahama Port Offshore 3km Upper Layer		Onahama Port Offshore 3km Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and Date of Sample Collection	2011/6/9 6:15		2011/6/9 6:15		2011/6/9 5:55		2011/6/9 5:55		2011/6/9 6:00		2011/6/9 6:00	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	5.5	0.09	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	7.3	0.08	5.4	0.06	ND	-	ND	-	90

Place of Sampling	Ena Offshore 3km Upper Layer		Ena Offshore 3km Lower Layer		Numanouchi Offshore 3km Upper Layer		Numanouchi Offshore 3km Lower Layer		Toyoma Offshore 3km Upper Layer		Toyoma Offshore 3km Lower Layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and Date of Sample Collection	2011/6/9 6:20		2011/6/9 6:20		2011/6/9 5:40		2011/6/9 5:40		2011/6/9 5:25		2011/6/9 5:25	
Detected Nuclides (Half-life)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	Density of Sample (Bq/cm3)	Scaling Factor (/)	
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	12	0.20	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	11	0.12	ND	-	ND	-	90

Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below measurable limit (approximately 6Bq/L for I-131), "ND" is stated.

Detection limits of the three main nuclides are as follows: I-131: approx. 6Bq/L, Cs-134: 15Bq/L, Cs-137: 15Bq/L

However, detection limits differs depending on the detectors and samples types, and therefore may be detected, under figures below.