

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on June 16)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	11:48 2011/6/15	11:45 2011/6/15	11:41 2011/6/15	11:42 2011/6/15	11:27 2011/6/15	11:19 2011/6/15	9:06 2011/6/15
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	ND	8. 2E-01	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	3. 7E+00	1. 1E+01	8. 4E-02	2. 9E-02	6. 8E-03	1. 4E-02	ND
Cs-137 (about 30 years)	4. 6E+00	1. 3E+01	8. 6E-02	ND	8. 2E-03	1. 6E-02	ND

※ O.OE—O means O.O×10.

※ Data of other nuclides are under evaluation.

※ ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 9E-3Bq/cm³, Cs-134: approx. 2E-2Bq/cm³, Cs-137: approx. 2E-2Bq/cm³). However, nuclides below limits might be detected since detection limits depend on d