

Fukushima Daiichi Nuclear Power Station Unit No. 2

Report on earthquake response analysis of the reactor building, important equipment and piping system for earthquake-resistant safety using observed seismic data during the Tohoku-Taiheiyou-Oki Earthquake in the year 2011 (Summary)

1. Introduction

We collected an abundance of seismic data based on observations of the reactor building's base mat etcetera on March 11th, 2011, the day the Tohoku-Taiheiyou-Oki earthquake struck.

In accordance with the instruction document* from the Nuclear and Industrial Safety Agency (hereafter NISA), we conducted an earthquake response analysis using the observed seismic data of Unit 2 of Fukushima Daiichi Nuclear Power Station. Hence, we are reporting the results of the analysis of the reactor building, important equipment and the piping system for earthquake-resistant safety.

* Instruction document

“Actions following the analysis of seismic data collected at Fukushima Daiichi nuclear power station and Fukushima Daini nuclear power station during the Tohoku-Taiheiyou-Oki Earthquake (Instruction)” (NISA No.6, March 16th, 2011)

2. Reactor building

We conducted an earthquake response analysis of Fukushima Daiichi Nuclear Power Station, Unit 2, utilizing the seismic data obtained from observations of the base mat with the objective of verifying the status of the building during the event.

The analysis used the proper building and ground models shown in Fig. 1.

As a result of the analysis, the maximum shear strain of the seismic wall was 0.43×10^{-3} (east-west direction, 5F), and the stress and strain were confirmed to be below the first knee point on the skeleton curve excluding the east-west wall of 5F as shown in Fig. 2 and Fig. 3.




Fig. 1 Model of Unit 2 reactor building




Fig. 2 Shear strain of seismic wall (south-north direction)




Fig. 3 Shear strain of seismic wall (east-west direction)

3. Important equipment and piping system for earthquake-resistant safety

We analyzed the earthquake responses of the large-size equipment such as the nuclear reactor of Unit 2 utilizing the observed data obtained during the earthquake. The results were compared to the seismic load etcetera provided by the seismic safety assessment using the defined design basis ground motion S_s .

It was found that some indexes such as the seismic load by the earthquake exceeded

the ones from the seismic safety assessment. We performed a seismic assessment of the major equipment which plays an important role on safety operations relevant to the “Stop” and “Cool-down” operations of the nuclear reactor and the “Containment” of radioactive materials. As a result, it was confirmed that the calculated stress etcetera were below the results given by the assessment.

Hence, it is presumed that the major equipment relating to safety operations are conditions that can maintain safety functions.





Fig. 4 Example of large equipment coupled earthquake response analysis

Table 1 Summary of the assessment of important equipment and the piping system for earthquake resistant safety (Fukushima Daiichi Nuclear Power Station, Unit 2)


Equipment		Earthquake response stress		design basis ground motion S _s	Simulation results	Results of seismic safety assessment
Seismic load and etc.	Reactor pressure vessel Base	Shear force (kN)		4960	5110	Reactor pressure vessel (foundation bolt) Calculated result: 29MPa Criterion: 222Mpa
		Moment (kN·m)		22500	25600	
		Axial force (kN)		5710	4110	
	Primary containm ent vessel Base	Shear force (kN)		7270	8290	Primary containment vessel (drywell) Calculated result: 87MPa Criterion: 278MPa
		Moment (kN·m)		124000	153000	
		Axial force (kN)		3110	2350	
	Core shroud Base	Shear force (kN)		2590	3950	Core supporter (shroud supporter) Calculated result: 122MPa Criterion: 300MPa
		Moment (kN·m)		13800	21100	
		Axial force (kN)		760	579	
	Fuel assembly	relative displacement (mm)		16.5	33.2	Control rod(insertion) Criterion: 40.0mm
Seismic intensity	Fuel exchange floor	Intensity (horizontal) (G)		0.97	1.21	Residual heat removal pump (motor mounting volt) Calculated result: 45MPa Criterion: 185Mpa
		Intensity (vertical.) (G)		0.56	0.70	
	Base mat	Intensity (horizontal) (G)		0.54	0.68	
		Intensity (vertical.) (G)		0.52	0.37	
Floor response spectrum (reactor building)	<p>< Middle layer (O.P.18.70m) ></p>					<p>Main steam system pipe Calculated result: 208MPa Criterion: 360MPa</p> <p>Residual heat removal system pipe Calculated result: 87MPa Criterion: 315MPa</p>

Floor response spectrum (reactor shield wall)

< Reactor shield wall base part (O.P.13.91m) >




(Horizontal)




(Vertical)

Reference: Summary of seismic assessment (Example of Main steam system pipe)



Floor response spectrum



Results of the structural strength assessment

Equipment	Part	Design basis ground motion Ss				This earthquake			
		Stress	Calcu. (MPa)	Criteria (MPa)	Method	Stress	Calcu. (MPa)	Criteria (MPa)	Method
Main steam system pipe	Pipe	Primary	288	360	Detail	Primary	208	360	Detail