

Reference
-----------

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <1/3>  
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June

Place of Collection	Shallow Draft Quay of 1F		Inside north water intake canal of 1F's Unit 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Screen of 1F's Unit 2 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	2011/6/26 6:58	2011/6/26 7:17	2011/6/26 7:20	2011/6/26 7:23	2011/6/26 7:31					
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-	89	2.2	78	2.0	80	2.0	80	2.0	40
Cs-134 (about 2 years)	99	1.7	390	6.5	410	6.8	380	6.3	370	6.2	60
Cs-137 (about 30 years)	100	1.1	430	4.8	420	4.7	430	4.8	410	4.6	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

Data of other nuclides are under evaluation.

In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

"ND" is stated in the case that density is below detectable threshold.

Detectable thresholds of the main 3 nuclides are as follows: I-131: approx. 11Bq/L.

Reference
-----------

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <2/3>  
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June 27)

Place of Collection	Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Screen of 1F's Unit 4 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)					
	Time and date of sample collection	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)		Scaling factor ( / )				
	2011/6/26 7:33			2011/6/26 7:40			2011/6/26 7:43			2011/6/26 7:47			2011/6/26 7:50			
I-131 (about 8 days)	1,600	40	210	5.3	150	3.8	210	5.3	190	4.8	40					
Cs-134 (about 2 years)	1,700	28	450	7.5	1,500	25	500	8.3	650	11	60					
Cs-137 (about 30 years)	1,800	20	440	4.9	1,600	18	520	5.8	700	7.8	90					

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".  
 Data of other nuclides are under evaluation.  
 In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

Reference

The Results of Nuclide Analyses of Radioactive Materials in the Seawater <3/3>  
 Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on June

Place of Collection	Inside the south of 1F's Unit 1-4 Water Intake Canal										Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
Time and date of sample collection	2011/6/26 7:57										
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	240	6.0	/	/	/	/	/	/	/	/	40
Cs-134 (about 2 years)	500	8.3	/	/	/	/	/	/	/	/	60
Cs-137 (about 30 years)	580	6.4	/	/	/	/	/	/	/	/	90

"Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".  
 Data of other nuclides are under evaluation.  
 In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1