

Results of Nuclide Analyses of Sub-drains

Reference

(Data summarized on July 7)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	12:10 am July 6, 2011	12:02 am July 6, 2011	1:05 pm July 6, 2011	11:47 am July 6, 2011	11:52 am July 6, 2011	11:45 am July 6, 2011	9:40 am July 6, 2011
Detected Nuclides (Half-life)	Radioactivity Density of Sample (Bq/cm ³)						
I-131 (about 8 days)	ND	1.6E-01	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	4.6E+00	1.1E+01	1.7E-01	ND	ND	ND	ND
Cs-137 (about 30 years)	5.5E+00	1.3E+01	1.8E-01	ND	ND	ND	ND

. E± means . ×10[±] .

Data of other nuclides are under evaluation.

ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 5E-2Bq/cm³, Cs-134: approx. 3E-2Bq/cm³, Cs-137: approx.4E-2Bq/cm³).

Please note that these nuclides are sometimes detected even when they are below the threshold, contingent on the detector or samples.