

Result of Nuclide Analysis of Sub-drain

Appendix

(Data summerized on July 8)

Place of Sampling	Fukusima Daiichi Nuclear Power Station Unit 2 Sub-drain	Fukusima Daiichi Nuclear Power Station Unit 5 Sub-drain
Date of Sample Collection	June 13, 2011	June 13, 2011
Detected Nuclides (Half-life)	Density of Sample (Bq/cm ³)	Density of Sample (Bq/cm ³)
I-131 (about 8 days)	9.2E-01	ND
Cs-134 (about 2 years)	1.0E+01	ND
Cs-137 (about 30 years)	1.2E+01	ND
Sr-89 (about 51days)	4.4E+01	4.1E-03
Sr-90 (about 29 years)	2.1E+01	1.1E-03

* " . E - " and " . × 1 0 - " have the same meaning.

* Announced I-131, Cs-134 and Cs-137 on June 14

* Analytical body: Japan Chemical Analysis Center (Sr-89, 90); TEPCO (I-131, Cs-134, Cs-137)

(Evaluation)

Sr-89 and 90 were detected and the influence of the accident is considered.