

Result of Nuclide Analysis of Radioactive Materials in the Air
at the Site of Fukushima Nuclear Power Stations

Reference

(Data Summarized on July 8)

Place of sampling	Around northwest ground of Fukushima Daiichi		West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)		Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to workers engaged in tasks associated with radiation) ²
Date and time of sampling	9:32 ~ 9:52 July 9, 2011		11:30 ~ 11:50 July 8, 2011		10:38 ~ 10:47 July 8, 2011		
Detected nuclide (half-life)	Radioactivity density ¹ (Bq/cm ³)	Scaling factor (/)	Radioactivity density ¹ (Bq/cm ³)	Scaling factor (/)	Radioactivity density ¹ (Bq/cm ³)	Scaling factor (/)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	3E-03

¹ The value of Radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

E - means $\times 10^E$

Data of other nuclides are under examination.

² In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.