

TEPCO Plant Status of Fukushima Daini Nuclear Power Station (as of 3:00 pm July 13, 2011)

Appendix

	Unit 1	Unit 2	Unit 3	Unit 4
Shutdown	Automatic shutdown ( at 2:48 pm on March 11th ) All control rods are all inserted	Automatic shutdown ( at 2:48 pm on March 11th ) All control rods are all inserted	Automatic shutdown ( at 2:48 pm on March 11th ) All control rods are all inserted	Automatic shutdown ( at 2:48 pm on March 11th ) All control rods are all inserted
Cooling	Residual heat removal system ( B ) is in operation ( From March 14th ) Residual heat removal system ( A ) was disabled due to the earthquake Cold shutdown * ( From March 14th )	Residual heat removal system ( B ) is in operation ( From March 14th ) Residual heat removal system ( A ) was disabled due to the earthquake Cold shutdown * ( From March 14th )	Residual heat removal system ( B ) is in operation ( From March 12th ) Residual heat removal system ( A ) was disabled due to the earthquake Cold shutdown * ( From March 12th )	Residual heat removal system ( B ) operating ( From March 14th ) Residual heat removal system ( A ) was disabled due to the earthquake Cold shutdown * ( From March 15th )
Containment	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30 ). ( On March 14th, achieved below 100 ) Containment vessel venting ( measurement to decrease the pressure in the containment vessel ) is not implemented	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30 ). ( On March 14th, achieved below 100 ) Containment vessel venting ( measurement to decrease the pressure in the containment vessel ) is not implemented	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30 ). ( Maintain below 100 as before the earthquake occurred ) Containment vessel venting ( measurement to decrease the pressure in the containment vessel ) is not implemented	No reactor coolant is leaked in the reactor containment vessel Water temperature in the suppression chamber is stable (generally 30 ). ( On March 14th, achieved below 100 ) Containment vessel venting ( measurement to decrease the pressure in the containment vessel ) is not implemented
Offsite power	Functioning	Functioning	Functioning	Functioning
Emergency power source system	Receiving electricity from the bus of emergency diesel generator ( B ) of Unit 2 Receiving electricity from the bus of emergency diesel generator ( B ) of Unit 3	Emergency diesel generator ( B )( H )	Emergency diesel generator ( B )( H )	Emergency diesel generator ( B ) ( H )
Others, any reports regarding abnormal matters	At 5:35 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( reactor coolant is leaked ( pressure in the reactor containment vessel increased ) ) At 6:33 pm on March 11th, determined no reactor coolant is leaked			
	At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( function of reactor coolant is lost ) At 1:24 am on March 14th, Residual heat removal system ( B ) is restored	At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( function of reactor coolant is lost ) At 7:13 am on March 14th, Residual heat removal system ( B ) is restored		At 6:33 pm on March 11th, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( function of reactor coolant is lost ) At 3:42 pm on March 14th, Residual heat removal system ( B ) is restored
	At 5:22 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( function of the suppression chamber is lost ) At 10:15 am on March 14th, the temperature in the suppression chamber achieved below 100	At 6:32 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( function of the suppression chamber is lost ) At 3:52 pm on March 14th, the temperature in the suppression chamber achieved below 100		At 6:07 am on March 12th, Occurrence of a Specific Incident Stipulated in Article 15 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( function of the suppression chamber is lost ) At 7:15 am on March 15th, the temperature in the suppression chamber achieved below 100
	At 10:07 pm on March 14th at the MP 1 and 12:12 am on March 15th at the MP 3, Occurrence of a Specific Incident Stipulated in Article 10 of the Act on Special Measures Concerning Nuclear Emergency Preparedness ( Increase in radiative material at the boundary ) due to the Influence by Fukushima Daiichi Nuclear Power Station. After 9:30 am April 3rd, radiation dose at the boundary of the site at Fukushima Daini Nuclear Power Station measured by MP remains below 5 μ Sv/h Regarding the result of measurement, please refer to TEPCO website at <a href="http://www.tepco.co.jp/en/nu/fukushima-np/f2/index-e.html">http://www.tepco.co.jp/en/nu/fukushima-np/f2/index-e.html</a>			
* : Cold shutdown . . . Achieved shutdown and maintain average water temperature below 100 in the Pressure Suppression Chamber.				