

Results of Nuclide Analysis of Radioactive Materials in the Air
at the Sites of Fukushima Nuclear Power Stations

Reference

(Data Summarized on July 21)

Place of sampling	Northeast of the Ground of Fukushima Daiichi		West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)		Density limit by the announcement of Reactor Regulation (Bq/cm ³) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2) 2
Date and time of sampling	2011/07/20 9:30 ~ 9:50		2011/07/20 11:30 ~ 11:50		2011/07/20 9:46 ~ 9:57		
Detected nuclide (half-life)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	Radioactivity density 1 (Bq/cm ³)	Scaling factor (/)	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	
Cs-134 (approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	3E-03

1 The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

. E - means . x 10⁻

Data of other nuclides are under examination.

2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.