## Nuclide Analysis Results of Seawater < Coast>

Reference

## (Data summarized on July 28)

Place of Sampling	North of Discha of 5-6u (approx. 30m n discharge o	of 1F north of 5-6u			arge Channel c -4u Discharge		Around North Channel ( Around 3,4u Chani ( approx. 10 k	of 2F I Discharge nel)	Around Iwasawa ( appox. 7 km : Discharge ( ( appox. 16 kr	south of 1,2u Channel)	Doncity limit by the
Time and Date of Sample Collection	July 27, 2011 10:15 am		July 27, 2011 10:00 am		NA		July 27, 2011 8:25 am		7:55 am		(the density limit in the water outside of
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Sample (Bq/L)	Scaling Factor ( / )	Density of Scaling Sample Factor (Bq/L) ( / )	surrounding monitored areas in the section 6 of the appendix 2)	
I-131 (about 8 days)	ND	-	ND	-			ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-			ND		ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-			ND	-	4.8	0.05	90

Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below measurable limit, "ND" is stated.

Detection limits of the three main nuclides are as follows: I-131: approx. 13Bq/L., Cs-134: approx. 32Bq/L, Cs-137: approx. 35Bq/L.

Please note that these nuclides are sometimes detected even when they are below the threshold, depending on the detector or sample characteristics.

## Results of Nuclide Analysis of Seawater < Offshore >

Reference

(Data summarized on: July 28)

											`		· · · · · · · · · · · · · · · · · · ·
Place of Sampling	30 km offshore of MinamiSouma City Upper layer		30 km offshore of MinamiSouma City Midde layer		30 km offshore of MinamiSouma City Lower layer		30 km offshore of Ukedo-gawa Upper layer		30 km offshore of Ukedo-gawa Middle layer		30 km offshore of Ukedo-gawa Lower layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the
Time and Date of Sample Collection	7:10 July 27, 2011		7:10 July 27, 2011		7:10 July 27, 2011		6:20 July 27, 2011		6:20 July 27, 2011		6:20 July 27, 2011		
Detected Nuclides (Half-life)	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	water outside of
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	5 km offshore of 3 Upper la	,		km offshore of Souma City Lower layer		5 km offshore of Kashima City Upper layer		5 km offshore of Kashima City Lower layer		3 km offshore of Souma City Upper layer		Souma City yer	announcement of
Time and Date of Sample Collection	5:15 July 27, 2011		5:15 July 27, 2011		5:35 July 27, 2011		5:35 July 27, 2011		4:55 July 27, 2011		4:55 July 27, 2011		Reactor Regulation (Bq/L) (the density limit in the
Detected Nuclides (Half-life)	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	Density of Sample ( Bq/cm3)	Scaling Factor	water outside of surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	ı	ND	-	ND	1	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L

Data of other nuclides are under evaluation.

In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

In the case that the data is below measurable limit, "ND" is stated.

Detection limits of the three main nuclides are as follows: I-131: approx. 3Bq/L, Cs-134: 5Bq/L, Cs-137: 5Bq/L

However, detection limits differs depending on the detectors and samples types, and therefore may be detected, under figures below.