

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <1/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 10)

Place of Collection	Shallow Draft Quay of 1F				Inside north water intake canal of 1F's Units 1-4		Screen of 1F's Unit 1 (outside the silt fence)		Screen of 1F's Unit 1 (inside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	
2011/8/9 6:29 AM	N/A				2011/8/9 6:40 AM		2011/8/9 6:47 AM		2011/8/9 6:52 AM		
Detected nuclide (half-life)	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	Density of sample (Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-	/	/	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	26	0.43	/	/	140	2.3	110	1.8	240	4.0	60
Cs-137 (about 30 years)	ND	-	/	/	180	2.0	110	1.2	290	3.2	90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 16Bq/L, Cs-137: approx. 29Bq/L), "ND" is represented.

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <2/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 10)

Place of Collection	Screen of 1F's Unit 2 (outside the silt fence)		Screen of 1F's Unit 2 (inside the silt fence)		Screen of 1F's Unit 3 (outside the silt fence)		Screen of 1F's Unit 3 (inside the silt fence)		Screen of 1F's Unit 4 (outside the silt fence)		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	
I-131 (about 8 days)	ND	-	60	1.5	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	120	2.0	1,100	18	210	3.5	1,600	27	240	4.0	60
Cs-137 (about 30 years)	160	1.8	1,200	13	240	2.7	1,700	19	270	3.0	90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 29Bq/L), "ND" is represented.

Reference
-----------

Nuclide Analysis Results of Radioactive Materials in Seawater <3/3>  
Fukushima Daiichi Nuclear Power Station; the shallow draft quay, Unit 1-4 screen, and the water intake canal of Units 1-4

(Data summarized on August 10)

Place of Collection	Screen of 1F's Unit 4 (inside the silt fence)		Inside the south of 1F's Units 1-4 Water Intake Canal		Port entrance of Fukushima Daiichi Nuclear Power Plant						Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of surrounding monitored areas in the section 6 of the appendix 2)
	Time and date of sample collection	2011/8/9 7:20 AM	2011/8/9 7:28 AM	N/A							
Detected nuclide (half-life)	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	Density of sample ( Bq/L)	Scaling factor ( / )	
I-131 (about 8 days)	ND	-	ND	-							40
Cs-134 (about 2 years)	820	14	71	1.2							60
Cs-137 (about 30 years)	870	9.7	96	1.1							90

\* "Density limit by the announcement of Reactor Regulation" shows the value in "Bq/ L" converted from the value originally in "Bq/ cm<sup>3</sup>".

\* Data of other nuclides are under evaluation.

\* In the case that there are multiple kinds of nuclides, compare the sum of each scaling factor against its density limit with 1

\* In case that radioactivity density in seawater in this analysis is below measurable threshold(I-131 : approx. 24Bq/L), "ND" is represented.