

Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference

(Data summarized on September 22)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	10:45 Sep 21 2011	10:50 Sep 21 2011	10:55 Sep 21 2011	10:06 Sep 21 2011	10:40 Sep 21 2011	10:35 Sep 21 2011	10:20 Sep 21 2011
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	3.7E+00	3.4E+00	3.9E-02	4.1E-02	ND	ND	ND
Cs-137 (about 30 years)	4.8E+00	4.4E+00	4.4E-02	3.7E-02	ND	ND	ND

* O.OE - O means O.O x 10-O

* Data of other nuclides are under evaluation.

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.