
Issues	Progress etc.	Reference (Photos and Figures)
(1)	[Unit 1] Improvement of working environment Removal of debris, measurement of radiation dose, entrance into buildings (May 9) RPV water level gauge calibration (May 10) PCV pressure gauge calibration (May 11) Installation of water level gauge at basement of Reactor Building (May 27) Installation of temporary RPV pressure gauge (Jun. 3)	Checking the reactor buildings by Packbot Measuring radiation dose inside the reactor buildings
(1) Reactor I. Cooling	Nitrogen gas injection Implementing from Apr. 6	Installing temporary RPV pressure gauge Nitrogen gas supply apparatus Nitrogen gas supply apparatus Supply apparatus System outline of nitrogen gas injection

Issues	Progress etc. Reference (Photos and Figures)			
(1) Reactor I. Cooling	Secure heat exchange function - Due to the leakage from the primary containment vessel (PCV), judged that it was difficult to secure water level of PCV. - Therefore, prioritize the achievement of circulation cooling of reactors by circulating water cooling. - For the reactor cooling facilities using heat exchanger, examining its implementation as mid to long term measures. (Work implemented) - Completed the assembly of cooling tower unit and shielding equipment to reduce exposure dose for outdoor work (from May 17 to Jun. 17)	[Under consideration] Outline of circulating cooling system within the reactor building Reactor Building		

Progress etc.	Reference (Photos and Figures)	
Cooling fuels at minimum water injection rate (Cooling by water injection) - Implementing water injection toward achieving cold shutdown condition. Sealing the leakage location Flooding the PCV	Image of flooding the PCV Inspection of reactor water level gauge Water injection to reactor Fuel	
- Under examination on the implementation as mid to long term measures. Consideration and preparation of reuse of accumulated water	Filling water up to the top of fuel range By Company of the top of fuel range of the top of fue	
 Work on injection line (from May 21) Started circulating water cooling from Jun. 27 Initiation and implementation of circulating water cooling Started circulating water cooling from Jun. 27 	Injection of freshwater Connection to feed water line Circulating water cooling Decontamination Outflow to T/B	
	Cooling fuels at minimum water injection rate (Cooling by water injection) - Implementing water injection toward achieving cold shutdown condition. Sealing the leakage location Flooding the PCV - Under examination on the implementation as mid to long term measures. Consideration and preparation of reuse of accumulated water - Work on injection line (from May 21) - Started circulating water cooling from Jun. 27 Initiation and implementation of circulating water cooling - Started circulating water cooling from	


Issues	Progress etc.	Reference (Photos and Figures)		
(1) Reactor I. Cooling	[Unit 2] Improvement of working environment Check on radiation dose, entry into buildings. (May 18, May 26, Jun. 4, Jun. 11) Started local exhausters, purification operation (from Jun. 11 to Jun. 19). Nitrogen gas injection In operation from Jun. 28. Secure heat exchange function Prioritize the achievement of circulation cooling of reactors by circulating water cooling. For the reactor cooling facilities using heat exchanger, examining its implementation as mid to long term measures. Study on sealing methodology of leakage location of Primary Containment Vessel. Conducted laboratory test on sealing methodology. Sealing the leakage location Flooding the PCV Under examination on the implementation as mid to long term measures. Cooling fuels at minimum water injection rate (cooling by water injection) Started operation of water injection through the core spray system from Sep. 14. Implementing water injection toward achieving cold shutdown condition. Consideration and preparation of reuse of accumulated water Construction of water injection line (from Apr. 9) Started circulating water cooling from Jun. 27. Initiation and implementation of circulating water cooling Started circulating water cooling from	Image of the countermeasure: Sealing the damaged location of Primary Containment Vessel. T/B Filling with grout material Discharge of the reactor building, filling the whole torus room with grout material.		

Iss	ues	Progress etc.	Reference (Photos and Figures)
I. Cooling	(1) Reactor	Improvement of working environment - Removal of debris, measurement of radiation dose, entrance into buildings. (May 18, Jun. 9) - Clearance work using robots (Jul. 1) - Placement of steal boards at truck bay door (Jul. 4) Nitrogen gas injection - In operation from Jul. 14. Secure heat exchange function - Prioritize the achievement of circulation cooling of reactors by circulating water cooling. For the reactor cooling facilities using heat exchanger, examining its implementation as mid to long term measures. Sealing the leakage location Flooding the PCV - Under examination on the implementation as mid to long term measures. Cooling fuels at minimum water injection rate (cooling by water injection) - Started operation of water injection through the core spray system from Sep. 1 Implementing water injection toward achieving cold shutdown condition.	Demolished and removed debris at the truck bay door, which would have been obstacles for installation of alternative cooling facilities for Unit 3 reactor. Truck bay door/ Inside Truck bay door/ Inside Machine hatch space on the 1st floor of the reactor building (After removal May 30) (After removal Jun. 4) Situation of demolishing and removing debris
		Consideration and preparation of reuse of accumulated water - Construction of water injection line (from Apr. 16) - Started circulating water cooling from Jun. 27. Initiation and implementation of circulating water cooling - Started circulating water cooling from Jun. 27.	Removal of outside pillars using wirelessly-controlled backhoe Removal of container loading using shielded forklift Container loading using shielded forklift




Issues	Progress etc.	Reference (Photos and Figures)		
	[Unit 2] Restoration of normal cooling system - In progress Installation of heat exchanger - Installation work of heat exchanger completed. Circulating cooling system is under operation (from May 31).	Debris in Unit 2 Waste Treatment Building Unit 2 Heat Exchanger Unit		
(2) Spent Fuel Pool I. Cooling	[Unit 3] Continuation of water injection by "Giraffe" etc	Unit 3 Spent Fuel Pool Unit 3 Heat Exchanger Unit		


Iss	ues	Progress etc.	Reference (Photos and Figures)
		Continuation of water injection by "Giraffe" etc - Reliability improvement: enhanced durability of hoses - Measures to reduce radiation dose: switch to remote-controlled operation - Installation of water level gauge (from Apr. 22)	Water injection by "Giraffe" at Unit 4
I. Cooling	(2) Spent Fuel Pool	Restoration of normal cooling system - Water injection by installing alternative equipment to "Giraffe" (from Jun. 17) - Switch to water injection line of circulating cooling system (from Oct. 3)	Injection hose (Metal flexible hose) Injection hose (Metal flexible hose) Alternative equipment to "Giraffe" at Unit 4
		Installation of heat exchanger - Installation work of heat exchanger completed. Circulating cooling system is under operation (from Jul. 31).	Alternative equipment to "Giraffe" at Unit 4 (as of Jun.17) Unit 4 Heat Exchanger Unit Air Fin Cooler




Issues Progress etc. Reference (Photos and Figures)		Reference (Photos and Figures)	
II. Miti	(3) Ac	[High level] Consideration of mitigation of contamination in the ocean - Completed setting up silt fence (Apr. 14) - Preparation work for setting steel pipe sheet piles [Completed removing curtain wall] - Purification of sea water by circulating purification system (from Jun. 13) - Completed setting up sliding concrete wall at intake of Units 1 to 4 (Jun. 29) - Work of placing steel pipe sheet pile (from Aug. 17 to Sep. 28) (Implemented in order to block the damaged parts of permeation prevention structure due to tsunami at the south side of intake canal of Units 1 to 4)	Adsorption of cesium by zeolites Valering pipe Circulating purification system Silt fence at intake (Unit 1 to 4) Silt fence at intake (Unit 2)
Mitigation	lated Water	Sliding concrete wall at intake (Before construction!)	Sliding concrete wall at intake (Setting work) Sliding concrete wall at intake (After construction) Sliding concrete wall at intake (Unit 2)
		Shipping steel pipe sheet pile	Placing steel pipe After placing steel pipe sheet pile (1) After placing steel pipe sheet pipe (2)

Issues	Progress etc.	Reference (Photos and Figures)		
(3) Accumulated Water II. Mitigation	[High Level] Containment of high level radioactive water - Closure of sea water piping vertical shaft Unit 2: completed on Jun. 2 Unit 3: completed on May 26 Unit 4: completed on Apr. 6 - Closure of pits, etc Unit 1: completed on May 17 Unit 2: completed on Jun. 9 Unit 3: completed on Jun. 10 Unit 4: completed on Jun. 10	Closure of sea water piping vertical shaft (fleft: before closure, right: after closure) Closure of sea water piping vertical shaft (fleft: before closure, right: after closure)		







Iss	ues	Progress etc.	Reference (Photos and Figures)		
		Consideration of mitigation measures of groundwater contamination - Closure of sea water piping vertical shaft Unit 2: Completed on Jun. 2 Unit 3: Completed on May 26 Unit 4: Completed on Apr. 6 - Closure of pits, etc. Unit 1: Completed on May 17 Unit 2: Completed on Jun. 9 Unit 3: Completed on Jun. 10 Unit 4: Completed on Jun. 10	Putting in crushed stones Concrete placement Mortar placement		
II. Mitigation	(4) Groundwater	 Restoration of sub drain pumps On T/B side Installation of pumps at sub drain pits. Completed at 7 points on Jul. 29 Completed laying the transfer piping arrangement on Aug. 31 On R/B side Considering locations to install the pumps Restoration of sub drain along with expansion plan of storage/processing facility. 	around 1m sub drain pit temporary water level gauge Image of restoration of sub drain pump		
		Construction of shielding wall of groundwater - Completed basic design of shielding wall on Aug. 31 - Under investigation of underground water level, water quality, etc. by boring Under study for sea side area in detail toward construction - Under investigation and study for landward area (~ step 2) <next step=""> - Begin construction for sea side area around the end of Oct.</next>	North breakwater East breakwater Shielding wall Landfill Landfill Permeable layer Standard cross-section view (A-A) Figure of basic plan of shielding wall Plain view		

Issu	es Progress etc.	Reference (Photos and Figures)	
	Dispersion of inhibitors		
	[Present Status] Completed dispersion of inhibitor -Record of dispersion: Approx. 560,000m2 <inside (flat="" and="" land="" power="" slope)="" station="">: Approx. 400,000m2 -Test dispersion (Apr. 1 to Apr. 25): Approx. 30,000m2 -Full dispersion (Apr. 26 to Jun. 28): Approx. 370,000m2</inside>	Dispersion of inhibitors in the Power Station (flat) Dispersion of inhibitors around Buildings of Units 1 to 4 Dispersion of inhibitors in the Power Station (flat)	
II. Mitigation	Around buildings>: Approx. 160,000m2 -Dispersion by crawler dump truck (Apr. 26 to Jun. 27) Around buildings of Units 1 to 4, 5 and 6: Approx. 120,000m2 -Dispersion by bending spray tower vehicle (May 27 to Jun. 4, Jun. 10) Turbine building of Units 1 to 4, roof and wall of reactor building of Unit 2: Approx. 30,000m2 -Dispersion by concrete pumping vehicle (Zebra) (Jun. 8,9,18) Roof and wall of reactor building of Units 1,3,4:Approx. 10,000m2		

We will keep monitoring status of solidification, etc. at dispersed areas.



Dispersion of inhibitors by bending spray tower vehicle




Dispersion of inhibitors by bending spray tower vehicle

Issu	Reference (Photos and		rence (Photos and Figures)		
		<u> </u>	Dispersion of inhibitors in the Power Station (flat) After dispersion of inhibitors		Dispersion of inhibitors in the Power Station (slope) After dispersion of inhibitors in the Power Station (slope)
				After dispersion of inhibitors in the Power Station (flat)	After dispersion of inhibitors in the Power Station (flat)

Removal and storage of debris - <removal debris="" of="">> - In order to mitigate exposure dose of the workers and improve work efficiency at the site, we have started removing the debris after storing them in the containers using remote-controlled heavy machinery (hydraulic shovel, crawler dump truck, bulldozer) (since Apr. 6). - The waste such as the removed debris and the trees cut down for site preparation are classified according to their kinds as well as the amount of radiation dose in the storage area and transported. - Almost all of the debris in highly-radioactive area outside the buildings of Units 1 to 4 (airborne radiation 10mSv/h or more) ware removed. Debris of roads, etc at the ocean side of the turbine buildings of Units 1 to 4 etc. was removed. -Record of removal of debris as of Oct. 17> - Approx. 900 containers of debris were collected. -Plan for further implementation> - We will continue removing outside debris, which hinders work. -<management debris="" of="">></management></removal>	Reference (Photos and Figures)		
- In order to mitigate exposure dose of the workers and improve work efficiency at the site, we have started removing the debris after storing them in the containers using remote-controlled heavy machinery (hydraulic shovel, crawler dump truck, bulldozer) (since Apr. 6). - The waste such as the removed debris and the trees cut down for site preparation are classified according to their kinds as well as the amount of radiation dose in the storage area and transported. - Almost all of the debris in highly-radioactive area outside the buildings of Units 1 to 4 (airborne radiation 10mSv/h or more) ware removed. Debris of roads, etc at the ocean side of the turbine buildings of Units 1 to 4 etc. was removed. - Record of removal of debris as of Oct. 17> - Approx. 900 containers of debris were collected. - Plan for further implementation> - We will continue removing outside debris, which hinders work. - We will continue removing outside debris, which hinders work.		Removal and storage of debris	
The debris is stored in containers and	(Example of container: 3.2×1.6 1.1m, approx. 4m³)	- In order to mitigate exposure dose of the workers and improve work efficiency at the site, we have started removing the debris after storing them in the containers using remote-controlled heavy machinery (hydraulic shovel, crawler dump truck, bulldozer) (since Apr. 6). - The waste such as the removed debris and the trees cut down for site preparation are classified according to their kinds as well as the amount of radiation dose in the storage area and transported. - Almost all of the debris in highly-radioactive area outside the buildings of Units 1 to 4 (airborne radiation 10mSv/h or more) ware removed . Debris of roads, etc at the ocean side of the turbine buildings of Units 1 to 4 etc. was removed. (5) - Record of removal of debris as of Oct. 17> - Approx. 900 containers of debris were collected. - Plan for further implementation> - We will continue removing outside debris, which hinders work. - Management of debris>> - Management of the storage area> - The debris is stored in containers and	Atmosphere /
buildings according to its amount of radiation dose etc., and workers are not able to approach to them easily. • The approach lane to the waste storage area is marked off and a sign has been installed that prohibits unnecessary entrance of unauthorized personnel. Around reactor building	ng of unit 1 (Jun. 9)	dose etc., and workers are not able to approach to them easily. • The approach lane to the waste storage area is marked off and a sign has been installed that prohibits unnecessary entrance	

Containers storing debris (mid May)



	Progres	s Status Cla	assified by Issues (Photos and	a Figures)
Issues	Progress etc.		Reference (Photos and	Figures)
	Removal/Storage of debris			
	Storage container / S		Storage container for debris	Container for small scale debris
(5) Atmosphere / Soil II. Mitigation			Container for large scale debris	Inside the storage tent for debris
	Storage yard in power s	ation (1)	Storage yard in power station (2)	Storage yard in power station (3)

Iss	ues	Progress etc.		Reference (Photos and Figures)		
II. Mitigation		Installation of reactor building cover Started preparation work * (from May 13) Maintenance of roads for a crane Creation of slope for crane to crawl Maintenance of shallow draft quay Started main structure construction work (from Jun. 28) Completion of steel-frame work of main structure (Aug.10-Sep. 9) Completion of installation of wall panels (Sep. 10-Oct. 10) Completion of installation of roof panel (Oct.8-Oct. 14) Started installation work of ancillary facilities such as exhauster and comprehensive test (from Oct. 14) Image of setting reactor building cover Model of constructing reactor building cover	(Maintenance of shallow draft quay, Co	on construction impleted laying out steel plate (Jun. 11)) Preparation	3 Lay out steel plate (5) Preparation construction (Maintenance of road for crawler crane)	
		woder or constructing reactor building cover	(Maintenance of road for crawler crane)	(Shallow draft quay - R	Road for crawler crane)	


	Progress Status Classified by Issues (Photos and Figures)					
Issu	Issues Progress etc Reference (Photos and Figures)					
				_	Main steel-frame work of main structure	
		Main steel-frame work of main structure	Start steel-frame work on Aug. 10	Completion of steel-frame work on Sep. 9 (Northwest side)	Setting wall panel as of Sep. 15 (Northwest side)	


Issues	Progress etc	Reference (Photos and Figures)
ue (5) Atmosphere / Soil II. Mitigation	[Unit 1] Setting reactor building cover Setting roof panel on Oct. 8	Reference (Photos and Figures) Completion of setting wall panel on Oct. 10 (North side) Setting roof panel on Oct. 14 Completion of setting roof panel on Oct. 14

Reference (Photos and Figures) Issues Progress etc. [Unit 3] Removal of debris on top of the reactor buildings Commencement of preparation work from Jun. 20 · Commencement of main work from ③ Preparation for iron-frame base yard ① Preparation work for reactor building cover Sep. 10 2 Preparation of roadbed for large-crane Camera equipped on the edge of a boom (5) Atmosphere / Soil Remote-controlled heavy Remote-controlled heavy machineries Status of demolition of pendant pillar at for dismantlement **Mitigation** west side of the reactor building Assembly of heavy machinery for Fixed camera Fixed camera dismantling debris around the building Remote-controlled large Status of demolition of the exhaust Image of removal of debris on top of the reactor building Preparation status at south side pipe at the top of the turbine building Status of removal of debris on top of the reactor Clearance of fallen debris at the south Ground preparation status (Installation Removal of debris at upper part of building building (Demolition of pendant pillar at west side) of pipe trench arrangement) and preparation status at south side side and around the building

		tatus Classified by Issues (Photos and Figures)
Issues	Progress etc.	Reference (Photos and Figures)
(5) Atmosphere / Soil II. Mitigation	[Unit 4] Removal of debris on top of the reactor buildings Commencement of preparation work from Jun. 24 Commencement of main work from Sep. 21 Image of removal of debris on top of the react building Installation of rest stations	The Preparation wantk for reactor building cover (a) Preparation of roadbed at large-crane working area (b) Removal of ground debris (c) Preparation of roadbed at large-crane working area (c) Removal of ground debris (d) Assembly of heavy machinery for removing debris around the reactor building

	1 Togress Status Classified by Issues (1 Hotos and 1 Igures)					
Issues	Progress etc.	Reference (Photos and Figures)				
(5) Atmosphere / Soil II. Mitigation	[Unit 4] Removal of debris on top of the reactor building	Retreat place and shield wall Removal of debris around the reactor building Removal of debris on upper part of operating floor Removal of debris on upper part of operating floor				





Iss	ues	Progress etc.		Reference (Photos and Fi	igures)
IV.		Expansion of countermeasures against Tsunami - Temporary EDGs were moved to the upland (Apr. 15) - Securing redundancy of water injection lines (by Apr. 15) - Setting fire engines on the upland (by Apr. 18)	Seaside area (height: 4m) 海側エリア (標準性) (標準性) (標準性) (相談 building area (height: 10m)	Areas for temporary tide barriers (planned) 仮設防潮堤 設置予定範囲 T/B #4T/B:	Cross-section of temporary tide barrier (image)
Countermeasures against aftershoo	(7) Tsunami, reinforcement, etc.	- Started installation of temporary tide barriers on May 18 and completed on Jun. 30		orary tide barrier otted line)	
hocks, etc.			Temporary tide barrier (1)	Temporary tide barrier (2)	Temporary tide barrier (3)

Issues	Progress etc.		Reference (Photos and Figu	ıres)
IV.	Expansion of countermeasures against Tsunami			
(7) Tsunami, reinforcement, etc. Countermeasures against aftershocks, etc.	Tide barrier of Unit 5/6	Temporary tide barrier (4) (construction work) Tide	Temporary tide barrier (5) barrier of Unit 5/6 (1)	Temporary tide barrier (6) Tide barrier of Unit 5/6 (2)

	. Togree status states by lesues (1 fields and 1 igui se)					
Iss	ues	Progress etc.		Reference (Photos and Figures)	
		Installation of supporting structure under the bottom of spent fuel pool	Outline of supporting structure		Removing debris	Securing route
		 Soundness of structure was analyzed and evaluated. Securing the route to the area to install supporting structure (removing debris, assembling a scaffolding at hatch, removing shield blocks) 	Steel pilla	r installation		
IV. Countermeasures against	(7) Tsunami,	Removing obstacles at the area and installing shielding Completion of installing steel pillars (Jun. 20) Completion of concrete placement (Jul. 26) Completion of pouring grout (completion of construction work) (Jul. 30)	Concrete w	vall installation	Removing debris at truck-bay door	Assembling a scaffolding at hatch
nst aftershocks, etc.	reinforcement, etc.	Installation of supporting structure under the bottom of spent fuel pool				
			Before work	Removing obstacles and installing shielding	Installing steel pillar (Jun. 15)	Steel pillar installation completed (Jun. 20)
		Ir	nstallation of frame for	Concrete placement	Installation of wire mesh	Grout pouring completed (Jul. 30)

ssues	Progress etc.	Reference (Ph	notos and Figures)
	Preparation of various	Preparation for installation of equipment	t at Fukushima Daiichi Nuclear Power Station
	countermeasures for radiation shielding		FIRST STATE OF THE
	 Utilization of Slurry> Slurry production facility, transfer pipes and concrete pumping vehicles have been installed. (May 17) 		
	Continue maintenance of equipmentImplemented water injection training	Overview of the facility	Slurry production facility
(7) Tsunami, reinforcemer	of connecting the slurry production facility and concrete pumping vehicle "Elephant-3" (Jun. 16 and 17) • Developed procedure documents and confirmed organizational structure (Jun. 30)		
ceme			ion of pipes ushima Daiichi Nuclear Power Station
nt, etc.	Installation of pipes	Preparation of equ	"Elephant-3"

High pressure concrete pumping vehicle

Installation of slurry plant at Fukushima Daiichi

Iss	ues	Progress etc.	Reference (Photos and Figures)				
		Continuing and enhancement of improvement of workers' living/working environment Double	deck beds (full-view)	Double-deck bed	Shower room	Drinks	
1				Gymnasium of F	Fukushima Daini		
V. Environment Improvement	(8) Living/working environment	iving/working environment of the servironment				Entrance	
)t	1ŧ	Full view (1)		Full view (2)	Full view (3)	Entrance	
		Room (1)	Room (2)	Room (3)	Room (4)	Floor	
				Shin Hirono Domitory			

ues	Progress etc.		Reference (Pho	tos and Figures)	
	improvement of workers' living/working environment				HIT.
	Shiri Hirono Domitory	Toilet/Shower house (full-view)	Inside of Toilet/Shower House (1)	Inside of Toilet/Shower House (2)	Outside Toilet
(8) Living/w					
orkir	Laundry house (full-view)	Inside of laundry house (1)	Dining house (A area)	Inside of dining house (1)	Inside of dining house (2)
ng environment	Inside of dining house (3)	Inside of dining house (4): Kitchen - 1	Inside of dining house (5): Kitchen - 2	Dining house (B area)	Inside of dining house (1)
	(8) Living/working environr	Laundry house (full-view) Laundry house (full-view)	improvement of workers' living/working environment Shin Hirono Domitory Toilet/Shower house (full-view) Laundry house (full-view) Inside of laundry house (1)	improvement of workers' living/working environment Shin Hirono Domitory Toilet/Shower house (full-view) Inside of Toilet/Shower House (1) Laundry house (full-view) Inside of laundry house (1) Dining house (A area)	improvement of workers' living/working environment Shin Hirono Domitory Toilet/Shower house (Itull-view) Laundry house (Itull-view) Inside of Toilet/Shower House (1) Laundry house (Itull-view) Inside of Iaundry house (1) Dining house (A area) Inside of dining house (1)


Issues	Progress etc.	Reference (Photos and Figures)		
(8) Living/working environment V. Environment Improvement	Continuing and enhancement of improvement of workers' living/working environment	Shin Hirono Domitory/Dining House Administration C		Shin Hirono Domitory/Dining House Shop
			Shin Hirono Domitory	


	Frogress Status Classified by Issues (Filotos and Figures)			
Issues	Progress etc.		Reference (Photos and Figures)	
	Continuing and enhancement of improvement of workers' living/working environment	Outside of Dining Room	Inside of Dining Room (1)	Inside of Dining Room (2)
(8) Living/working environment V. Environment Improvement		Shop	Inside of J Village	


	Progress Status Classified by Issues (Photos and Figures)					
Issues Progress etc. Reference (Photos and Figures)						
		Improvement of workers' living/working environment Installation of on-site rest rooms Enhancement of on-site rest rooms and restoration of existing facilities				
V. Environment Improven	(8) Living/working	Rest rooms (in front of Main Anti-earthquake Building)	Entrance of Main Anti- earthquake Building (Unit house for access control)	Entrance of Main Anti- earthquake Building (from the inside)		vity measurement in earthquake Building
Improvement	g environment	Inside of rest room (1)	Drink server	Rest rooms		
		Inside of rest room (2)	Rest room in front of Anti- earthquake Building		nk servers oom of a partner company (Toshiba)	Inside of rest room

Reference (Photos and Figures) Progress etc. Issues Improvement of workers' living/working environment Inside (1): Drink server Inside (2) Outside of rest room Rest room near heliport Rest room for workers for covering reactor buildings Outside V. Environment Improvement (8) Living/working environment Installation of rest rooms Entrance Outside Outside of rest room (1) Inside Rest room in Office of Main Anti-Survey Inside earthquake Building (second Rest room of a partner company phase) Outside of rest room (2) (Hitachi GE)

Reference (Photos and Figures) Issues Progress etc. **Enhancement of Radiation Control** Improvement of protective equipment Protective equipment appropriate to work environment is provided in order to secure safety during radiation work. *Source: vendor catalogue Special protective gear: Closed-circuit oxygen breathing apparatus: Protective suit which can be expected It can realize a long 120-minute usage, circulating aspirated air to shield beta ray and low-energy with oxygen inside the cylinder. It is suitable for usage in oxygen-less hazardous area. gamma ray (9) Radiation control / Medical care V. Environment Improvement SA *Source: vendor Half-faced mask: *Source: vendor catalogue Respiratory protective device with electric fan: In case that radioactivity density is The mask can blow in cleaned air which is filtered with electric low and stable, workers put on fan. Internal pressure is kept higher than environmental half-face masks, not full-face, pressure in order to reduce the risk of inhaling particulate. (with goggles), which enables to Also, it realizes to breathe freely and lighten loss of bodily lighten the workload of workers. strength. *Source: vendor catalogue Keeping the inner pressure positive, the mask prevents influx of outer air. Continuous ventilation helps exhausting the inner humidity and prevents heat injuries.







Issues	Progress etc.	Reference (Photos and Figures)		
(9) Radiation control / Medical care V. Environment Improvement	Continuing enhancement of radiation control - Reinforced radiation controlling Alarm Pocket Dosimeters had been lent through signing in a recording book and entered the data manually into database, but worker identification cards with barcodes have been provided since Jun. 8 so that it becomes possible to enter the data directly into the database with barcode readers. From Aug. 16, radiation exposure data are printed out in receipts. We are planning to introduce a system which can automatically acquire individual radiation exposure data of workers at J-village.	(After Improvement (corrent condition) 】 1. Lending Alarm Pocket Dosimeter and signing in a recording book - Lending pocket dosimeter and signing the annease, time, etc. in a recording book manage personal in-and-out. 2. Working, carrying pocket dosimeter and measuring - Measurement with pocket dosimeter and signing the annease personal in-and-out. 3. Entering measurement results in the book and PC - Entering data of time, radation exposure, etc. in the book or PC when leaving the area. - Entering data of time, radation exposure, etc. in the book or PC when leaving the area. - Entering data of time, radation exposure, etc. in the book or PC when leaving the area. - Entering data of time, radation exposure, etc. in the book or PC when leaving the area. - Entering data of time, radation exposure data. - Entering data of time, radation exposure exposure data. - Entering have radation exposure expos		

		Fiogress	Status Classified by Issues (Photos and Figures)	1
Iss	ues	Progress etc.	Reference (Photos and Figures)	
		Continuing improvement of medical system		
		- ER for Unit 5/6 established for the temporary use during the summer only is now used as a permanent facility, staffed by emergency specialists continuously after September.		
· .	(9) ا	- Nurse(s) and radiation technologist(s) have also been allocated, though on irregular basis for the time being.	Medical Space at Main Anti-Earthquake Building	
. Environment Improvement	ion control /	- Enhancement of medical facilities and reinforcement of decontamination facilities have met the conditions to transport patients promptly; it enabled us to transport seriously ill patients who are not contaminated to hospitals directly.	現場 (本代 対応	
/ement	cal ca	Ambulance cars have been prepared at 1F (Sep. 16) *Three (3) carriers in total	Cool Vest Mask with blower Cool Vest	er Cool Scurf
		Prevention of influenza infection and spreading at 1F (Starting vaccination for influenza, etc. from Nov. 1.)	THE STATE OF THE S	ATTEKS !
		Countermeasures against heatstroke Notice board Cool vest Mask with floor Cool scurf	Wearing Cool Scurf Wearing Cool Pack for Neck (Freezed type)	(1 100200 typo)
			**Photos are from manufacturers' brochures. Ther	e are cases diferent from actual use.

Iss	ues	Progress etc.	Reference (Photos and Figures)
		Continuing improvement of medical system	Emergency Room (ER) for Unit 5/6
V. Environment Improveme	(9) Radiation control / Medical	Operation check of medical devi	Inventory check of medial drugs (doctor and nurse) Radiation dose measurement in the room (radiation technologist) ER for Unit 5/6 (medical space)
nent	care		Training of screening and decontamination of a patient (in front of the entrance of the service bldg of Unit 5/6)

Iss	ues	Progress etc.	Reference (Photos and Figures)
		Continuing improvement of medical system JV Clinic External Appearance	
V. Environment Improvement	(9) Radiation control / Medical care	Deployed Ambulance	Ambulance and Patient Carrier

	Progress Status Classified by Issues (Photos and Figures)				
Issues	Progress etc.	Reference (Photos and Figures)			
(10) Staffing Plan V. Environment Improvement	-Launched a new framework of looking for workers widely through Japan Atomic Industrial Forum (JAIF), according to affiliated	Radiation survey staff training course (at training center, TEPCO) Radiation survey staff training center, TEPCO)			
		Radiation protection staff training course (at JAEA)			