Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference

(Data summarized on October 25)

| Place of Sampling | Fukushima Daiichi NPS 1U sub-drain | | | | Fukushima Daiichi NPS 5U sub-drain | | |
|----------------------------------|---------------------------------------|---------------------|---------------------|---------------------|---------------------------------------|---------------------|---------------------|
| Time of Sampling | 2011/10/24 10:30 | 2011/10/24 10:35 | 2011/10/24 10:50 | 2011/10/24 10:21 | 2011/10/24 10:25 | 2011/10/24 10:20 | 2011/10/24 09:55 |
| Detected Nuclides (Half-life) | Density of sample (Bq/cm3) | | | | | | |
| l-131 (about 8 days) | ND | ND | ND | ND | ND | ND | ND |
| Cs-134 (about 2 years) | 7.2E-01 | 7.2E-01 | ND | ND | ND | ND | ND |
| Cs-137 (about 30 years) | 9.7E-01 | 9.1E-01 | 3.2E-02 | ND | ND | ND | ND |

* 0.0E - 0 means 0.0 x 10-0

* Data of other nuclides are under evaluation.

* "ND" means the sampled data is below measurable limit. I-131: approx. 4E-2Bq/cm3, Cs-134: approx. 3E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3) Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.