

## Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference
-----------

(Data summarized on November 3)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	2011/11/2 9:35 AM	2011/11/2 9:40 AM	2011/11/2 9:45 AM	2011/11/2 9:52 AM	2011/11/2 9:30 AM	2011/11/2 9:25 AM	2011/11/2 9:05 AM
Detected Nuclides (Half-life)	Density of sample ( Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	6.2E-01	1.6E+00	ND	ND	ND	ND	ND
Cs-137 (about 30 years)	8.6E-01	2.1E+00	2.5E-02	ND	ND	ND	ND

\* O.OE - O means  $O.O \times 10^{-O}$

\* Data of other nuclides are under evaluation.

\* "ND" means the sampled data is below measurable limit.

I-131: approx.  $3E-2Bq/cm^3$ , Cs-134: approx.  $3E-2Bq/cm^3$ , Cs-137: approx.  $3E-2Bq/cm^3$ )

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.