

## Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference
-----------

Data summarized on November 8)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain	Fukushima Daiichi NPS 2U sub-drain	Fukushima Daiichi NPS 3U sub-drain	Fukushima Daiichi NPS 4U sub-drain	Fukushima Daiichi NPS 5U sub-drain	Fukushima Daiichi NPS 6U sub-drain	Fukushima Daiichi NPS Deep well
Time of Sampling	2011/11/7 10:15 AM	2011/11/7 10:20 AM	2011/11/7 10:30 AM	2011/11/7 9:47 AM	2011/11/7 10:10 AM	2011/11/7 10:05 AM	2011/11/7 (Not sampled)
Detected Nuclides (Half-life)	Density of sample ( Bq/cm3)						
I-131 (about 8 days)	ND	ND	ND	ND	ND	ND	-
Cs-134 (about 2 years)	2.1E+00	1.4E+00	2.8E-02	ND	ND	ND	-
Cs-137 (about 30 years)	2.7E+00	1.9E+00	3.1E-02	ND	ND	ND	-

\* O.OE - O means  $O.O \times 10^{-O}$

\* Data of other nuclides are under evaluation.

\* "ND" means the sampled data is below measurable limit.

I-131: approx.  $3E-2Bq/cm^3$ , Cs-134: approx.  $3E-2Bq/cm^3$ , Cs-137: approx.  $3E-2Bq/cm^3$  )

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.