Nuclide Analysis Results of Seawater <Coast>

Reference

(Data summarized on November 9)

Place of Sampling	North of Discha of 5-6u (approx. 30m n discharge o	of 1F orth of 5-6u	Around South Channel (appox. 330m Discharge (of 1F south of 1-4u	Around North Channel (Around 3,4u Chanr (approx. 10 ki	of 2F I Discharge nel)	Around Iwasawa (appox. 7 km s Discharge ((appox. 16 kr	south of 1,2u Channel)	Density limit by the announcement of Reactor Regulation (Bq/L)	
Time of Sampling	Nov 08, 08:40		Nov 08, 08:15		Nov 08, 08:30		Nov 08, 08:05		(the density limit in the water outside of	
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	surrounding monitored areas in the section 6 of the appendix 2)	
l-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	40	
Cs-134 (about 2 years)	3.1	0.05	1.9	0.03	1.3	0.02	1.7	0.03	60	
Cs-137 (about 30 years)	5.2	0.06	3.9	0.04	1.8	0.02	1.8	0.02	90	

* yDensity by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit.

I-131: approx. 0.65Bq/L

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.

Results of Nuclide Analysis of Seawater <Offshore 1/2>

Reference

(Data summarized on November 9)

Place of Sampling	15 km offshore of15 km offshore ofMinami-SoumaMinami-SoumaCityUpper layerCityLower layer		15 km offshore of Ukedo-gawa Upper layer		15 km offshore of Ukedo-gawa Lower layer		15 km offshore of Fukushima Daiichi Upper layer		15 km offshore of Fukushima Daiichi Lower layer		Density limit by the announcement of		
Time of Sampling	N/A		N/A		Nov 07, 2011 (Not sampled)		Nov 07, 2011 (Not sampled)		Nov 07, 2011 (Not sampled)		Nov 07, 2011 (Not sampled)		Reactor Regulation (Bq/L) (the density limit in the water outside of
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90

Place of Sampling	15 km offsh Fukushima Da layer	ini Upper			15 km offshore of Iwasawa Shore Upper layer		15 km offshore of Iwasawa Shore Lower layer		15 km offshore of Hirono-town Upper layer		15 km offshore of Hirono-town Lower layer		Density limit by the announcement of Reactor Regulation (Bq/L) (the density limit in the water outside of
Time of Sampling	Nov 07, 2 (Not samp		,		N/A		N/A		N/A		N/A		
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	areas in the section 6 of the appendix 2)
I-131 (about 8 days)	-	-	-	-	-	-	-	-	-	-	-	-	40
Cs-134 (about 2 years)	-	-	-	-	-	-	-	-	-	-	-	-	60
Cs-137 (about 30 years)	-	-	-	-	-	-	-	-	-	-	-	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

Results of Nuclide Analysis of Seawater < Offshore 2/2>

Reference

(Data summarized on November 9)

Place of Sampling	3 km offshore of North of Iwaki Upper layer Iwaki Lower layer		3 km offshore of Natsui river Upper layer		3 km offshore of Natsui river Lower layer		3 km offshore of Onahama port Upper layer		3 km offshore of Onahama port Lower layer		Density limit by the announcement of		
Time of Sampling	Nov 07, 2011 07:55 am		Nov 07, 2011 07:55 am		Nov 07, 2011 07:15 am		Nov 07, 2011 07:15 am		Nov 07, 2011 06:10 am		Nov 07, 2011 06:10 am		Reactor Regulation (Bq/L) (the density limit in the water outside of
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	surrounding monitored areas in the section 6 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	90

Place of Sampling	3 km offshore of Ena Upper layer Lower layer			3 km offsho Numanouchi U		3 km offshore of Numanouchi Lower layer		,		3 km offshore of Toyoma Lower layer		Density limit by the announcement of	
Time of Sampling	Nov 07, 2011 06:50 am		Nov 07, 2011 06:50 am		Nov 07, 2011 06:50 am		Nov 07, 2011 06:50 am		Nov 07, 2011 06:35 am		Nov 07, 2011 06:35 am		Reactor Regulation (Bq/L) (the density limit in the water outside of
Detected Nuclides (Half-life)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	Density of Sample (Bq/L)	Scaling Factor (/)	areas in the section 6 of the appendix 2)
I-131 (about 8 days)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	40
Cs-134 (about 2 years)	ND	-	ND	-	ND	-	ND	-	ND	-	ND	-	60
Cs-137 (about 30 years)	ND	-	ND	-	0.94	0.01	ND	-	ND	-	ND	-	90

* Density by the announcement of Reactor Regulation is stated with an amount converted from Bq/cm3 to Bq/L.

* Data of other nuclides are under evaluation.

* In the case that two or more kinds of nuclides exist, sum of each scaling factor to the density limit is compared with 1.

* "ND" means the sampled data is below measurable limit. I-131: approx. 0.73Bq/L, Cs-134: approx. 0.99Bq/L, Cs-137: approx. 1.1Bq/L detected even when they are below the limits, contingent on the detector or samples.

Please note that these nuclides are sometimes