

福島第一・1号機 原子炉注水量低減時の原子炉格納容器温度

操作ステップ : ステップ2
 操作完了時刻 : 2017/1/5 10:45

原子炉格納容器温度は、原子炉注水低減における各ステップの操作完了後、24時間は1時間毎(正時)のデータ監視を行うこととしており、温度データに異常がみられない場合は、通常の監視頻度(6時間毎)に移行することとしている。

計器 日 時	原子炉格納容器温度(°C)											
	TE-1625A	TE-1625B	TE-1625C	TE-1625D	TE-1625E	TE-1625F	TE-1625G	TE-1625H	TE-1625J	TE-1625K	TE-1625T3	TE-1625T6
2017/1/5 10:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.6	17.8
2017/1/5 11:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.8	20.7	17.6	17.8
2017/1/5 12:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.8	20.7	17.7	17.8
2017/1/5 13:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.6	17.8
2017/1/5 14:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.5	17.8
2017/1/5 15:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.5	17.8
2017/1/5 16:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.8	20.7	17.6	17.8
2017/1/5 17:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.7	17.6	17.9
2017/1/5 18:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.4	19.7	20.7	17.7	17.9
2017/1/5 19:00	17.2	16.8	16.7	16.8	16.8	16.6	16.7	23.5	19.7	20.6	17.7	17.9
2017/1/5 20:00	17.2	16.7	16.7	16.8	16.8	16.6	16.7	23.4	19.7	20.6	17.7	17.8
2017/1/5 21:00	17.2	16.7	16.7	16.8	16.8	16.6	16.7	23.4	19.7	20.6	17.6	17.8
2017/1/5 22:00	17.1	16.7	16.7	16.8	16.8	16.5	16.7	23.4	19.7	20.6	17.6	17.8
2017/1/5 23:00	17.1	16.7	16.6	16.7	16.8	16.5	16.6	23.4	19.7	20.6	17.5	17.8
2017/1/6 0:00	17.1	16.7	16.6	16.8	16.8	16.5	16.6	23.3	19.7	20.6	17.5	17.8
2017/1/6 1:00	17.1	16.7	16.6	16.7	16.8	16.5	16.6	23.3	19.7	20.6	17.6	17.8
2017/1/6 2:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.6	17.6	17.8
2017/1/6 3:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.8
2017/1/6 4:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.8
2017/1/6 5:00	17.1	16.7	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.9
2017/1/6 6:00	17.1	16.6	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.7	17.9
2017/1/6 7:00	17.1	16.6	16.6	16.7	16.7	16.5	16.6	23.3	19.6	20.5	17.6	17.8
2017/1/6 8:00	17.1	16.6	16.6	16.7	16.7	16.5	16.5	23.3	19.6	20.5	17.5	17.8
2017/1/6 9:00	17.0	16.6	16.6	16.7	16.7	16.4	16.5	23.2	19.5	20.4	17.5	17.7
2017/1/6 10:00	17.0	16.6	16.6	16.6	16.7	16.4	16.5	23.2	19.5	20.5	17.5	17.7
2017/1/6 11:00	17.0	16.6	16.5	16.6	16.7	16.4	16.5	23.3	19.5	20.5	17.5	17.8