

<参考資料>
 平成24年2月8日
 東京電力株式会社

福島第一原子力発電所2号機 原子炉压力容器下部(底部ヘッド上部)温度について

日時	1F2 原子炉压力容器下部(底部ヘッド上部)温度 /		
	TE-2-3-69H1	TE-2-3-69H2	TE-2-3-69H3
2/1 23:00	52.0	44.5	43.9
2/2 5:00	52.4	44.5	43.9
2/2 11:00	52.9	44.6	44.1
2/2 17:00	54.6	44.6	44.2
2/2 23:00	55.7	44.7	44.3
2/3 5:00	57.4	44.8	44.4
2/3 11:00	58.0	44.8	44.5
2/3 17:00	61.0	44.8	44.6
2/3 23:00	62.6	45.0	44.8
2/4 5:00	64.5	45.3	45.0
2/4 11:00	64.8	45.2	45.1
2/4 17:00	65.1	45.7	45.2
2/4 23:00	66.1	45.6	45.3
2/5 5:00	67.4	45.6	45.2
2/5 11:00	68.6	45.6	45.0
2/5 17:00	69.4	45.3	44.8
2/5 23:00	70.3	44.9	44.6
2/6 5:00	70.6	44.7	44.3
2/6 11:00	71.0	44.1	43.9
2/6 17:00	69.2	43.9	43.5
2/6 23:00	69.9	43.6	43.2
2/7 5:00	72.2	43.1	42.8
2/7 11:00	69.6	42.2	42.0
2/7 17:00	68.5	41.3	41.0
2/7 23:00	67.4	40.6	40.3
2/8 5:00	66.7	40.0	39.7