

福島第一原子力発電所2号機 原子炉压力容器下部(底部ヘッド上部)温度

| 日時 | 1F2 原子炉压力容器下部(底部ヘッド上部)温度 / | | |
|-----------|----------------------------|------------------------|------------------------|
| | TE-2-3-69H1 (0 °) | TE-2-3-69H2 (135 °) | TE-2-3-69H3 (270 °) |
| 2/1 23:00 | 52.0 | 44.5 | 43.9 |
| 2/2 5:00 | 52.4 | 44.5 | 43.9 |
| 2/2 11:00 | 52.9 | 44.6 | 44.1 |
| 2/2 17:00 | 54.6 | 44.6 | 44.2 |
| 2/2 23:00 | 55.7 | 44.7 | 44.3 |
| 2/3 5:00 | 57.4 | 44.8 | 44.4 |
| 2/3 11:00 | 58.0 | 44.8 | 44.5 |
| 2/3 17:00 | 61.0 | 44.8 | 44.6 |
| 2/3 23:00 | 62.6 | 45.0 | 44.8 |
| 2/4 5:00 | 64.5 | 45.3 | 45.0 |
| 2/4 11:00 | 64.8 | 45.2 | 45.1 |
| 2/4 17:00 | 65.1 | 45.7 | 45.2 |
| 2/4 23:00 | 66.1 | 45.6 | 45.3 |
| 2/5 5:00 | 67.4 | 45.6 | 45.2 |
| 2/5 11:00 | 68.6 | 45.6 | 45.0 |
| 2/5 17:00 | 69.4 | 45.3 | 44.8 |
| 2/5 23:00 | 70.3 | 44.9 | 44.6 |
| 2/6 5:00 | 70.6 | 44.7 | 44.3 |
| 2/6 11:00 | 71.0 | 44.1 | 43.9 |
| 2/6 17:00 | 69.2 | 43.9 | 43.5 |
| 2/6 23:00 | 69.9 | 43.6 | 43.2 |
| 2/7 5:00 | 72.2 | 43.1 | 42.8 |
| 2/7 11:00 | 69.6 | 42.2 | 42.0 |
| 2/7 17:00 | 68.5 | 41.3 | 41.0 |
| 2/7 23:00 | 67.4 | 40.6 | 40.3 |
| 2/8 5:00 | 66.7 | 40.0 | 39.7 |
| 2/8 11:00 | 66.0 | 39.5 | 39.2 |
| 2/8 17:00 | 65.4 | 39.1 | 38.7 |
| 2/8 23:00 | 68.1 | 38.7 | 38.3 |

| 日時 | 1F2 原子炉压力容器下部(底部ヘッド上部)温度 / | | |
|------------|----------------------------|------------------------|------------------------|
| | TE-2-3-69H1 (0 °) | TE-2-3-69H2 (135 °) | TE-2-3-69H3 (270 °) |
| 2/9 5:00 | 67.9 | 38.2 | 37.9 |
| 2/9 11:00 | 66.8 | 37.8 | 37.6 |
| 2/9 17:00 | 65.6 | 37.5 | 37.2 |
| 2/9 23:00 | 65.8 | 36.9 | 36.8 |
| 2/10 5:00 | 66.7 | 36.3 | 36.5 |
| 2/10 11:00 | 68.0 | 36.6 | 36.0 |
| 2/10 17:00 | 67.5 | 36.5 | 35.9 |
| 2/10 23:00 | 69.5 | 36.3 | 35.7 |
| 2/11 5:00 | 68.5 | 36.1 | 35.6 |
| 2/11 11:00 | 70.0 | 35.9 | 35.4 |
| 2/11 17:00 | 69.5 | 35.8 | 35.3 |
| 2/11 23:00 | 74.9 | 35.6 | 35.1 |
| 2/12 5:00 | 75.4 | 35.4 | 35.0 |
| 2/12 11:00 | 75.4 | 34.3 | 34.8 |
| 2/12 17:00 | 81.5 | 34.6 | 34.3 |
| 2/12 23:00 | 81.0 | 33.8 | 33.8 |
| 2/13 5:00 | 89.6 | 33.4 | 33.2 |