

福島第一原子力発電所2号機 原子炉格納容器内温度の状況(6時間データ)
 [HP掲載:プラント関連パラメータの抜粋]

	return air drywell cooler(TE- 16-114A)	return air drywell cooler(TE- 16-114B)	return air drywell cooler(TE- 16-114C)	return air drywell cooler(TE- 16-114D)	return air drywell cooler(TE- 16-114E)	supply air D/W cooler(TE- 16-114F#1)	supply air D/W cooler(TE- 16-114G#1)	supply air D/W cooler(TE- 16-114H#1)	supply air D/W cooler(TE- 16-114J#1)
単位									
2012/5/27 23:00	55.7	46.8	47.1	42.5	45.7	42.7	46.4	53.5	46.1
2012/5/28 5:00	55.9	46.8	47.2	42.6	45.7	42.5	46.4	53.3	46.1
2012/5/28 11:00	56.3	46.8	47.2	42.8	45.7	42.6	46.4	53.2	46.2
2012/5/28 17:00	58.0	46.8	47.1	43.7	45.7	41.0	46.4	52.1	46.1
2012/5/28 23:00	64.7	46.7	47.1	47.6	45.6	35.0	46.3	48.2	46.0
2012/5/29 5:00	65.1	46.7	47.1	47.3	45.5	35.0	46.3	48.1	46.0
2012/5/29 11:00	59.1	46.1	47.1	43.9	45.5	39.9	46.2	51.5	45.9
2012/5/29 17:00	57.6	46.5	47.0	43.2	45.5	41.1	46.2	52.3	46.0
2012/5/29 23:00	57.1	46.6	47.1	43.0	45.5	41.3	46.3	52.6	46.0
2012/5/30 5:00	56.4	46.5	46.8	42.6	45.3	41.8	46.1	52.8	45.9
2012/5/30 11:00	56.2	46.5	46.8	42.6	45.3	42.0	46.1	52.8	45.9
2012/5/30 17:00	55.8	46.4	46.8	42.5	45.3	42.2	46.1	52.8	45.8
2012/5/30 23:00	55.6	46.4	46.8	42.4	45.3	42.2	46.1	52.8	45.8
2012/5/31 5:00	55.6	46.4	46.8	42.2	45.4	42.6	46.1	52.7	45.8
2012/5/31 11:00	55.4	46.3	46.7	42.1	45.3	42.5	46.0	52.6	45.7
2012/5/31 17:00	55.4	46.3	46.6	42.0	45.2	42.2	45.9	52.7	45.7
2012/5/31 23:00	55.4	46.5	46.7	42.0	45.3	42.4	46.0	52.7	45.7
2012/6/1 5:00	55.2	46.3	46.7	42.0	45.3	42.4	46.0	52.8	45.7
2012/6/1 11:00	55.3	46.3	46.6	42.0	45.2	42.2	45.9	52.6	45.6
2012/6/1 17:00	55.2	46.3	46.7	41.9	45.2	42.6	45.9	52.7	45.6
2012/6/1 23:00	55.3	46.3	46.7	42.0	45.3	42.4	45.9	52.8	45.6
2012/6/2 5:00	55.4	46.4	46.7	42.1	45.2	42.2	45.9	52.7	45.7
2012/6/2 11:00	55.5	46.3	46.7	42.2	45.2	42.3	45.9	52.7	45.6
2012/6/2 17:00	55.7	46.4	46.7	42.3	45.3	42.1	45.9	52.6	45.6
2012/6/2 23:00	55.8	46.4	46.8	42.5	45.3	42.0	46.0	52.6	45.7
2012/6/3 5:00	56.7	46.0	46.8	43.2	45.9	41.2	46.1	52.2	45.8
2012/6/3 11:00	57.9	46.4	46.7	44.2	46.0	39.7	46.0	51.4	45.7
2012/6/3 17:00	58.3	46.4	46.7	44.4	45.9	39.2	46.0	51.3	45.8
2012/6/3 23:00	59.2	46.4	46.7	45.1	46.0	37.9	46.1	50.8	45.8
2012/6/4 5:00	64.3	46.4	46.6	47.3	45.9	34.6	46.0	48.2	45.7
2012/6/4 11:00	64.0	46.4	46.6	47.1	46.0	34.9	46.0	48.1	45.7
2012/6/4 17:00	64.0	46.1	46.7	47.2	46.1	34.8	46.1	48.0	45.8
2012/6/4 23:00	63.6	46.3	46.7	47.1	45.2	35.0	46.0	47.9	45.7
2012/6/5 5:00	63.5	46.4	46.7	47.2	45.3	35.0	46.1	48.0	45.8
2012/6/5 11:00	63.5	46.3	46.7	47.3	46.0	35.1	46.1	48.1	45.8
2012/6/5 17:00	63.8	46.2	46.7	47.2	45.2	35.1	46.0	48.0	45.8
2012/6/5 23:00	63.5	46.4	46.8	47.4	45.3	35.1	46.1	48.2	45.8
2012/6/6 5:00	63.5	46.3	46.8	47.2	45.3	35.4	46.1	48.3	45.8
2012/6/6 11:00	64.4	46.1	46.9	47.1	45.3	35.2	46.0	48.2	45.8
2012/6/6 17:00	64.6	46.1	46.8	47.1	45.3	34.8	46.0	48.1	45.7
2012/6/6 23:00	64.7	46.1	46.8	47.1	45.3	34.9	46.0	48.1	45.7
2012/6/7 5:00	64.5	46.1	46.8	47.2	45.3	34.4	46.0	48.1	45.7
2012/6/7 11:00	64.8	46.1	46.8	47.0	45.3	34.9	46.1	48.2	45.8
2012/6/7 17:00	65.0	46.3	46.9	47.1	45.3	34.8	46.1	48.1	45.8
2012/6/7 23:00	65.1	46.4	46.8	47.0	45.3	35.5	46.1	48.2	45.8
2012/6/8 5:00	64.6	46.4	46.8	47.0	45.3	35.7	46.1	48.4	45.8
2012/6/8 11:00	64.3	46.4	46.8	46.9	45.4	36.0	46.2	48.6	45.8

: 今回指示値の大きな変動が見られた温度計